

FIRE BUREAU
SOUTH ORANGE VILLAGE
PREVENTION/INSPECTION/EDUCATION

codeinspectorfire@southorange.org
P 973.378.7715 ext. 7709
F 973.378.5830
www.southorange.org

76 South Orange Ave
Suite 302
South Orange
Essex County
New Jersey 07079



NJ UNIFORM FIRE CODE: COOKING VENDOR GUIDELINES

- The following are minimum guidelines for each cooking vendor at festivals, carnivals, etc.
- A site plan may be required by the Fire Official prior to event.

FIRE SAFETY PERMIT:

Cooking vendor permits – a permit application shall be submitted through The Township of South Orange Village Fire Bureau for each vendor for every event. N.J.A.C. 5:70-2.7(a); All cooking vendors shall be required to apply for a fire safety permit through the Township of South Orange Village Fire Bureau. Type-1 Permit Fee \$54.00-NO CASH will be accepted. Permits will not be issued unless payment is made in full. This is an application processing fee and is not refundable. N.J.A.C. 5:70-2.7(f); The fire official upon inspection may deny or revoke a permit at any time; this can be due to failure to meet the permit conditions, unabated fire code violations or unsafe conditions.

FIRE EXTINGUISHER:

All cooking vendors shall supply their own fire extinguishers. N.J.A.C. 5:70-3, 906.2; All fire extinguishers shall comply with NFPA 10/2002. All fire extinguishers shall have a valid dated inspection tag, good of one year.

N.J.A.C. 5:70-3, 904.11.5; Class K portable fire extinguishers are required for cooking with vegetable or animal oils and fats.

N.J.A.C. 5:70-3, 904.11.5.1; Class K portable fire extinguishers are required for cooking with solid fuel.

N.J.A.C. 5:70-3, 904.11.5.2; Class K portable fire extinguishers required for deep fat fryers. (See 2006 IFC-NJ for size and quantity)

PROPANE TANK:

N.J.A.C. 5:70-3, 3003.5.3; Propane tanks shall be secured, to prevent falling over.

N.J.A.C. 5:70-3, 3801.1; Propane tanks and equipment shall comply with NFPA 58/2004.

N.J.A.C. 5:70-3, 3803.2.1; Propane tanks shall not be taken into buildings/tents, (see 2006-1 for exceptions)

Mobile Canteens & Cooking Trailers: N.J.A.C. 5:70-4.7(g) All cooking operations that produce grease laden vapors shall be equipped with a ventilating hood, duct, and automatic fire suppression system.

N.J.A.C. 5:70-3, 904.6; Dry chemical extinguishing systems shall be maintained and inspected semi-annually as per NFPA 17/2002.

N.J.A.C. 5:70-3, 904.5; Wet chemical extinguishing systems shall be maintained and inspected semi-annually as per NFPA 17A/2002.

N.J.A.C. 5:70-3, 609.2; Excessive grease and residue buildup on kitchen exhaust systems, cleaning required.

MISCELLANEOUS:

N.J.A.C. 5:70-3, 104.3; All appliances shall be listed and labeled and approved by the fire code official. (No homemade appliances).

N.J.A.C. 5:70-3, 2403.8.2; No vehicles shall be parked within 5 feet of tents or canopies.

N.J.A.C. 5:70-3, 2404.15.3; Suitable barricades shall be provided to maintain a distance of 5 feet between the heat producing appliance and the public.

- Propane tanks between 4 and 40 lbs shall have an Overfill Protection Device for filling in NJ.
- Propane tanks shall be hydro tested every 12 years, and not dented or badly rusted.
- Regulator shall be in good condition and the relief valve shall face away from the public areas.
- All plastic type protective caps shall be removed from all propane tanks before operating.
- Hoses shall not be frayed or cracked, and there shall not be any type of tape on the hose.
- Hoses shall not be covered with grease and shall not be swollen. • Hoses shall not create a tripping hazard
- Only approved lighter fluid shall be used for charcoal grills.
- Sterno warmers may be used provided the fuel containers are properly protected from being knocked over and if the fuel containers are properly enclosed within the warmer units.